



Rod height will be determined by tank depth.

Adjustable Float  
 Float height will be set equal to or just above the on position of the timer enable float in the STEP system.

	GRAVITY LINES
	PRESSURE LINES
	QUANICS COMPONENTS
	NON-QUANICS COMPONENTS
	TEXT/ADIES

QUANICS CONTACTS - TECHNICAL		AUTOCAD DRAWINGS	
BRIAN BORDERS, R.S.	ERIC SHELDON	TOM JENKINS	
502-492-4214	502-492-4235	502-492-4216	
Borders@quatics.net	ESheldon@quatics.net	TJenkins@quatics.net	
TOM PETTY, P.O., R.E.I.S.	KEVIN SHERMAN, P.E., PH.D.		
615-288-4399	502-492-4212		
TPetty@quatics.net	KSherman@quatics.net		

PRODUCT(S) COVERED BY ONE OR MORE U.S. AND/OR INTERNATIONAL PATENTS. OTHER U.S. AND/OR INTERNATIONAL PATENTS MAY BE PENDING.		SCALE	DRAWN BY	NAME	DATE
		1 : 20	TP	TP	04-24-07
		N/A	TECHNICAL APPROVAL	KS	04-24-07
			ENGINEER APPROVAL		
P.O. BOX 1520 CRESTWOOD KY 40014 877-QUANICS - www.quatics.net					